



JDR
Electrical

JDR Electrical
15 The Rookery
Madeley
Telford
Shropshire
TF7 5AN
Office: 01952 929568
Mobile: 07791135071
Email: james@jdrelectrical.co.uk





Inspection & Testing In Accordance To The IET Code of Practice for In-Service Inspection and Testing of Electrical Equipment: 5th Edition 2020



Testing carried out in accordance to Health and Safety At Work Act 1974, the Management of Health And Safety At Work Regulation 1999, the Electricity at Work Regulation 1989, the Workplace (Health, Safety and Welfare) Regulation 1992 and the Provision and Use of Work Equipment Regulation 1998.

PAT Testing Certificate

DETAILS OF CLIENT

Client: Made You Look Photo Booth (Benedict Wilkins)
Address: 5 The Grove, Wellington Road, Coalbrookdale, Telford, Shropshire, TF8 7EN

TEST EQUIPMENT DETAILS

Test Equipment used	SEAWARD PRIMETEST 250+	Serial Number	30M-0630		
Tested by	J. Robinson	Date	13/06/2023	Retest Date	13/06/2024

Serial Number	Make and model	Location	Voltage (V)	Rating (A)	Fuse rating (A)	Insulation resistance	Earth continuity	Plug, flex and body	OK to use ?
1	WOODEN PHOTO BOX	TF8 7EN	230v	13A	5A	>200MΩ	-	PASS	YES
2	IEC LEAD	TF8 7EN	230v	13A	3A	>200MΩ	<0.1Ω	PASS	YES
3	4WAY EXT REEL	TF8 7EN	230v	13A	13A	>200MΩ	<0.1Ω	PASS	YES
4	PRINTER	TF8 7EN	230v	13A	3A	>200MΩ	-	PASS	YES
5	4WAY EXT REEL	TF8 7EN	230v	13A	3A	>200MΩ	<0.1Ω	PASS	YES
6	IEC LEAD	TF8 7EN	230v	13A	5A	>200MΩ	<0.1Ω	PASS	YES
7	D-LITE RX2	TF8 7EN	230v	13A	3A	>200MΩ	<0.1Ω	PASS	YES